



- A. Room Infrastructure Row
 1. Modular PDUs ala APC PDPM144F – 300mm
 2. Potential UPS options
 3. Networking/Network Services
 4. Row arrangement is not final
- B. Electrical Panel
- C. APC ACRC/ACRP 500 InRow Chiller
- D. Air Curtains for Hot/Cold Aisle
 1. Note Buffer Zones between Hot/Cold
- E. ISO-Base Seismic Isolation Planks
- F. APC AR3100 600mm x 1070mm 42U

 Underfloor Clearance

 Work Area Clearance

20" deep concrete shelf under floor

