

- A. Room Infrastructure Row
 1. Modular PDUs ala APC PDPM144F – 300mm
 2. Potential UPS options
 3. Networking/Network Services
 4. Row arrangement is not final
- B. Electrical Panel
- C. APC Uniflair Chiller (Example)
 1. 130KW Model - 28" clearance in front
 2. must have underfloor clearance for airflow
- E. ISO-Base Seismic Isolation Planks
- F. APC AR3100 600mm x 1070mm 42U

